

## PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 1266

Dated: 05/04/2025

It is certified that an inspection team headed by ..... DATA RAM .....

(Name of Officers with designation) from ..... Assistant Engineer .....

(Name of Department/ Office) inspected the Campus Public School, Dariyapur Bujurg .....

(Name & Address of the school) on 05/04/25 ..... (date of inspection) and found that the Campus Public School ..... (Name of school) has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

The above is valid for a period of 1 year from the issued date

Signature with Seal: ..... दाशराम  
सहायक अभियन्ता  
उ०प्र० जल निगम (ग्रामीण)

Name : ..... DATA अभियन्ता .....

Designation : ..... Assistant Engineer .....

Name & Address of the Office / Department : U.P. Jal  
Nigam, Amroha

To

Campus Public School  
Dariyapur Bujurg, Gajraula, Distt Amroha.

(Name &amp; Address of the Institution)

Principal  
Campus Public School  
Dariyapur Bujurg Gajraula  
Amroha (U.P.)

गुरेग और  
Manager  
Campus Public School  
Gajraula (Amroha)





By E-Mail  
E-Mail ID cdupjn\_amroha@yahoo.com

कार्यालय  
अधिशाली अभियन्ता, खण्ड कार्यालय, उ०प्र० जल निगम (ग्रामीण),  
अमरोहा - 244221

पत्रांक 1266 /प्रयोगशाला अमरोहा/ 11 दिनांक 05-04-2025  
सेवा में,

Campus Public School  
Dariyapur Bujurg Gajraula  
Amroha


विषय- पानी की जांच के संबंध में।

महोदय,

उपरोक्त विषयक Campus Public School Vill Dariyapur Bujurg Gajraula Dist. Amroha दिनांक 04.04.2025 को लाये गये पेयजल नमूने की जांच खण्डीय प्रयोगशाला में की गयी। जांचोंपरान्त जांच रिपोर्ट संलग्न कर प्रेषित है।

संलग्नक:- उपरोक्तानुसार।


भवदीय

  
(चन्द्रहास)



अधिशाली अभियन्ता


पृ०सं० एवं दिनांक उपरोक्तानुसार।

प्रतिलिपि:- सहायक अभियन्ता/जू०इंजी० लैब को सूचनार्थ हेतु प्रेषित।

  
Principal  
Campus Public School  
Dariyapur Bujurg Gajraula  
Amroha (U.P.)

  
Manager  
Campus Public School  
Gajraula (Amroha)

  
अधिशाली अभियन्ता  


  
सहायक अभियन्ता  
उ०प्र० जल निगम (ग्रामीण)  
अमरोहा



# ANALYSIS REPORT

District Level Water Analysis Laboratory U.P, Jal Nigam (Rural) Amroha  
Address- Atrasi to Joya bypass Road near R.T.O Office Amroha Uttar Pradesh Pin-244221



Report No.	1266	Date	05/04/2025	Page No.	
Customer Details					
Office Name and Address	Campus Public School, Dariyapur Bujurg, Gajraula				
Ref Letter No & date					
Basic details of sample					
District	Amroha	Block	Gajraula		
Gram Panchayat	Dariyapur Bujurg	Village	Dariyapur Bujurg		
Habitation	Dariyapur Bujurg	Location	Dariyapur Bujurg		
Water Source	R.O. Plant	Sample No.	AMR/C/25/02		
Quantity of Sample	1 Lt	Date of S.C	04/04/2025		
Receiving Date	04/04/2025	Sample Collector	Lalit Kumar		
Sample Submit	04/04/2025	Sampling Method Used	IS 17614 (Part 1):2024		
Analysis	Chemist/Lab Assistant				
Analysis Start Date	05/04/2025	Analysis Completion date-	05/04/2025		

## Environmental Condition

Temperature	25±3°C	Relative Humidity	Upto 50±15
-------------	--------	-------------------	------------

## Technical Data of Analysis

S.R	Analysed Parameters (Unit of Measurement)	Observed Value	Specified Values as per IS 10500:2012		Ref Method of Analysis
			Acceptable Limit	Permissible Limit	
1	2	3	4	5	6
1	Colour (HU)	5	5	15	IS 3025 P-4:2021
2	pH	8.05	6.5-8.5	6.5-8.5	IS 3025 P-11:2022
3	TURBIDITY (NTU)	1.86	1.0	5.0	IS 3025 P-10:2023
4	TDS (mg/l)	303.6	500	2000	IS 3025 P-16:2023
5	CHLORIDE (mg/l)	54.98	250	1000	IS 3025 P-32:2019
6	TOTAL ALKALINITY (mg/l)	220.00	200	600	IS 3025 P-23:2023
7	TOTAL HARDNESS(mg/l)	238	200	600	IS 3025 P-21:2019
8	Calcium (mg/l)	15.23	75	200	IS 3025 P-40:2019
9	Magnesium (mg/l)	42.78	30	100	IS 3025 P-46:2019
10	Fluoride (mg/l)	0.213	1.0	1.5	Apha23th edition-4500 F <sup>-</sup> Method C (Electrode method):2023

## Note -

1. This Certificate refers only to the particular sample(s) submitted for testing..
2. This Certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory.
3. The test results reported in this certificate are valid at the time of send under the stated conditions of measurements.
4. Sample will be stored up to 7 days. (in case of non-perishable items only) from the date of issue of tests report unless.

Principal  
Campus Public School  
Dariyapur Bujurg Gajraula  
Amroha (U.P.)

मुख्य अधिकारी  
Manager  
Campus Public School  
Gajraula (Amroha)

दलीप राम  
सहायक अभियन्ता  
उत्तर प्रदेश जल निगम (ग्रामीण)

Authorized Signatory  
District Level Water Analysis Laboratory  
UP, IN

End Of The Report





# BACTERIOLOGICAL ANALYSIS REPORT

## DISTRICT LEVEL WATER ANALYSIS LABORATORY

U.P, JAL NIGAM (RURAL) AMROHA

Address- Khand karyalay, Atrasi to Joya bypass Road Amroha Uttar Pradesh Pin-244221

Report No.	1266	Date	05/04/2025	Page No.	1
<b>Customer Details</b>					
Office Name and Address	Campus Public School, Dariyapur Bujurg, Gajraula				
Ref Letter No & date					
<b>Basic details of sample</b>					
District	Amroha	Block	Amroha		
Gram Panchayat	Dariyapur Bujurg	Village	Dariyapur Bujurg		
Habitation	Dariyapur Bujurg	Location	Dariyapur Bujurg		
Water Source	R.O. Plant	Sample No.	AMR/B/25/02		
Quantity of Sample	1000 ML	Date of S.C	04/04/2025		
Receiving Date	04/04/2025	Sample Collector	Lalit Kumar		
Sample Submit	04/04/2025	Sampling Method Used	IS 17614 (Part 1):2024		
Analysis	04/04/2025				
Analysis Start Date	04/04/2025	Analysis Completion date-	04/04/2025	Result Availability Date-	05/04/2025

### Technical Data of Analysis

S.N	Analysed Parameters (Unit of Measurement)	Unit	Observed Value	Specified Values as per IS 10500:2012		Ref Method of Analysis
				Acceptable Limit	Permissible Limit	
1	2	3	4	5	6	7
1	E.COLI	CFU	Not Found	Shall not be detectable in 100 ml Sample		APHA 23 <sup>rd</sup> Edition : 2017
2	T.COLI	CFU	Not Found	Shall not be detectable in 100 ml Sample		APHA 23 <sup>rd</sup> Edition : 2017

### Note -

1. This Certificate refers only to the particular sample(s) submitted for testing..
2. This Certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory.
3. The test results reported in this certificate are valid at the time of send under the stated conditions of measurements.
4. Sample will be stored up to 7 days. (in case of non-perishable items only) from the date of issue of tests report unless.

Principal  
Campus Public School  
Dariyapur Bujurg Gajraula  
Amroha (U.P.)

Manager  
Campus Public School  
Gajraula (Amroha)

सहायक अभियन्ता  
उत्तर प्रदेश जल निगम (ग्रामीण)  
अमरोहा

(Microbiologist)  
Authorized Signatory

End Of The Report.....